

Certificate

No. c7219a-22

Customer:

TKM GmbH
Schlossstraße 123
41238 Mönchengladbach, Germany

Category 6A

Test sample(s):

Connecting hardware:

KSM - keystone module - Cat.6A - STP - HD - AWG23-26

KSM - keystone module - Cat.6A - STP - HD - AWG22-24

Part no.: 467768210 (AWG23-26)
467768212 (AWG22-24)

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

IEC 60603-7-51 Ed.1.0 (2010-03)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.


Connecting hardware, Copper, Category 6A

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **R7219a-22** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 09.02.2022


Dirk Wilhelm, engineer
(Chairman of the Managing Board)

**GHMT AG**

In der Kolling 320
66450 Bexbach / Germany

PO box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**